

Caldwell Water Department
One Provost Square
Caldwell, NJ 07006
Annual Drinking Water Quality Report
Caldwell Water Department
For the Year 2018, Results from the Year 2017

The Caldwell Water Department is pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

The Borough receives its drinking water through an agreement with the Borough of Essex Fells. Essex Fells has sixteen wells which draw groundwater from the Watchung Basalt, Brunswick Shale, and Stratified Glacial Drift. The wells range in depth from 94 to 566 feet and provide the majority of our drinking water throughout the year. In 2017 Essex Fells also purchased water from New Jersey American Water. Water Quality test results for the Essex Fells Water Department and New Jersey American Water are included in this report. The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for these public water systems, which are available at www.state.nj.us/dep/swap or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The Caldwell Water Department, the Essex Fells Water Utility and New Jersey American Water routinely monitor for contaminants in your drinking water according to Federal and State laws. The tables show the results of that monitoring for the period of January 1st to December 31st, 2017. The state allows monitoring for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative, are more than one year old.

Caldwell Water Department Test Results						
PWS ID #NJ0703001						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Copper Test results Yr. 2015 Result at 90 th Percentile	N	0.11 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Test results Yr. 2015 Result at 90 th Percentile	N	2.6 No samples exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection Byproducts:						
TTHM Total Trihalomethanes Test results Yr. 2017	N	Range = 7 - 11 Highest detect = 11	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2017	N	Range = ND - 1 Highest detect = 1	ppb	N/A	60	By-product of drinking water disinfection
Regulated Disinfectants		Level Detected		MRDL		MRDLG
Chlorine Test results Yr. 2017		Average = 0.6 ppm		4.0 ppm		4.0 ppm

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

DEFINITIONS:

In the "Test Results" tables you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the contaminant.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Organic Compounds - Chemicals associated with carbon or living matter.

No Standard (NS) - No standard has been established for this parameter

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Secondary Contaminant - Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance.

Secondary standards are recommendations, not mandates.

Recommended Upper Limit (RUL) - Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RUL's are recommendations, not mandates.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health.

MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Total Organic Carbon - Total Organ Carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts. The *Treatment Technique* for TOC requires that 35% - 45% of the TOC in the raw water is removed through the treatment processes.

Turbidity - Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium microbial growth. Turbidity is measured as an indication of the effectiveness of the filtration process. The *Treatment Technique* for turbidity requires that no individual sample exceeds 1 NTU and 95% of the samples collected during the month must be less than 0.3 NTU.

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Caldwell Water Department and Its suppliers are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at <http://www.epa.gov/safewater/lead>.

Special considerations regarding children, pregnant women, nursing mothers, and others:

Children may receive a slightly higher amount of a contaminant present in the water than do adults, on a body weight basis, because they may drink a greater amount of water per pound of body weight than do adults. For this reason, reproductive or developmental effects are used for calculating a drinking water standard if these effects occur at lower levels than other health effects of concern. If there is insufficient toxicity information for a chemical (for example, lack of data on reproductive or developmental effects), an extra uncertainty factor may be incorporated into the calculation of the drinking water standard, thus making the standard more stringent, to account for additional uncertainties regarding these effects. In the cases of lead and nitrate, effects on infants and children are the health endpoints upon which the standards are based.

If you have any questions about this report or concerning your water utility, please contact Paul Carelli Borough Administrator at 973-403-4634. Always feel free to attend one of the regularly scheduled Borough Council meetings. The Mayor and Council meet regularly the first and third Tuesday of each month at One Provost Square at 7:00PM.

We at the Caldwell Water Department work hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.

Essex Fells Water Utility - 2017 Test Results PWS ID #NJ0706001						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Arsenic Test results Yr. 2015	N	Range = ND – 0.98 Highest detect = 0.98	ppb	n/a	5	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium Test results Yr. 2015	N	Range = 0.14 – 0.32 Highest detect = 0.32	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium Test results Yr. 2015	N	Range: 0.73 – 3.5 Highest Level = 3.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper Result at 90 th Percentile Test results Yr. 2015	N	0.1 No samples exceeded the action level.	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits.
Lead Result at 90 th Percentile Test results Yr. 2015	N	2.9 No samples exceeded the action level.	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Mercury (inorganic) Test results Yr. 2015	N	Range = 0.04 – 0.06 Highest detect = 0.06	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nitrate (as Nitrogen)	N	Range: 1.6 – 2.8 Highest detect = 2.8	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection By-Products:						
HAA5 Haloacetic Acids	N	Range = 1 - 8 Highest LRAA = 4	ppb	N/A	60	By-product of drinking water disinfection
TTHM Total Trihalomethanes	N	Range = ND – 19 Highest LRAA = 10	ppb	N/A	80	By-product of drinking water disinfection
Radioactive Contaminants:						
Gross Alpha	N	Range = ND – 4.4 Highest detect = 4.4	pCi/l	0	15	Erosion of natural deposits
Regulated Disinfectants		Level Detected		MRDL		MRDLG
Chlorine		Average = 0.5 ppm		4.0 ppm		4.0 ppm

TTHM compliance is based on a Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

New Jersey American Water – Short Hills System is a public community water system consisting of 25 wells, 4 surface water intakes, 12 purchased ground water sources, 3 purchased surface water sources. Source water comes from the following aquifers and / or surface water bodies: Passaic River, Brunswick Aquifer System, and Canoe Brook

New Jersey American Water conducts annual sampling to determine the radon levels in all sources of our water supply. Our water showed radon levels ranging from non-detectable to 1059 pCi/l in the Short Hills System. The EPA is developing regulations to reduce Radon in drinking water. Radon in the air is inexpensive to test and easy to remediate. For Additional information, call the EPA's Radon Hotline at 1-800-SOS-Radon. Radon is a radioactive gas that occurs naturally in some groundwater.

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

Cryptosporidium is a microbial pathogen found in surface water throughout the United States. Although filtration removes Cryptosporidium, the most commonly-used filtration methods cannot guarantee 100% removal. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants and small children, and the elderly are at a greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water. New Jersey American Water conducted a two year study of their water supply to determine the amount of Cryptosporidium in untreated raw water. Monthly samples were taken from July 2003 to June 2005 and analyzed. Cryptosporidium was not detected in any samples.

New Jersey American Water – Short Hills System - 2017 Test Results						
PWS ID # NJ0712001						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
Microbiological Contaminants:						
Total Organic Carbon	N	Range = 1.1 – 1.6 Average removal 1.3	ppm	N/A	TT % of removal	Naturally present in the environment.
Turbidity	N	Range = 0.02 – 0.26 100% samples < 0.3	NTU	0	TT = % of samples < 0.3	Soil runoff
Inorganic Contaminants:						
Copper Result at 90 th Percentile Test results December 2017	N	0.32 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride	N	Range = ND – 0.36 Highest detect = 0.36	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead Result at 90 th Percentile Test results December 2017	N	3 1 sample out of 103 exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	Range = ND – 22 Highest detect = 22	ppb	N/A	N/A	Erosion of natural deposits
Nitrate (as Nitrogen)	N	Range = 0.31 – 6.18 Highest detect = 6.18	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection Byproducts:						
TTHM Total Trihalomethanes	N	Range = 8.6 – 92.4 Highest LRAA = 92.4	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Range = 6.0 – 52.7 Highest LRAA = 52.7	ppb	N/A	60	By-product of drinking water disinfection
Radioactive Contaminants:						
Gross Alpha	N	Range = ND – 13.1 Highest detect = 13.1	pCi/l	0	15	Erosion of natural deposits
Combined Radium 228 & 226	N	Range = ND – 3.19 Highest detect = 3.19	pCi/l	0	5	Erosion of natural deposits
Regulated Disinfectants;		Level Detected	MRDL		MRDLG	
Chlorine		Range = 0.5 – 1.0 ppm	4.0 ppm		4.0 ppm	

HAA5 and TTHM compliance is based on the Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

New Jersey American Water – Short Hills System Test Results Year 2017			
PWS ID # NJ0712001			
Secondary Contaminant	Level Detected	Units of Measurement	RUL
Sodium	Range = 14 - 94	ppm	50
Manganese	Range = ND - 156	ppb	50

New Jersey American Water – Short Hills System exceeded the Recommended Upper Limit (RUL) for Sodium. For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the Recommended Upper Limit (RUL) may be of concern to individuals on a sodium restricted diet.

New Jersey American Water – Short Hills System exceeded the secondary Recommended Upper Limit (RUL) for manganese which is based on staining of laundry. Manganese is an essential nutrient, and toxicity is not expected from levels which would be encountered in drinking water. Manganese is a naturally occurring element in soil, groundwater, and some surface waters. Manganese is considered harmless to health, however, they may give water an off taste or color, cause splotchy yellow stains on laundry, and clog water systems.

Unregulated Contaminant Monitoring Rule (UCMR)

New Jersey American Water participated in the UCMR. Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether regulation is warranted. Our results are available upon request. For testing conducted in the Short Hills System, we found the substances listed.

Contaminant	Level Detected	Units of Measurement	Likely source
1,4-Dioxane Test results Yrs. 2013, 2014 & 2015	Range = ND – .24	ppb	Cyclic aliphatic ether; used as a solvent or solvent stabilizer in manufacturing and processing of paper, cotton, textile products, automotive coolant, cosmetics and shampoos
Chlorate Test results Yrs. 2013, 2015	Range = ND – 200	ppb	Agricultural defoliant of desiccant; disinfection byproduct; used in the production of chloride dioxide
Chromium (VI) Test results Yrs. 2013 & 2015	Range = ND – 1.7	ppb	Naturally-occurring element; used in the making of steel and other alloys; chromium -3 or -6 are used for chrome plating, dyes and pigments, leather tanning, and other wood preservation
Cobalt Test results Yrs. 2013 & 2015	Range = ND – 2.3	ppb	Naturally-occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water; cobaltous chloride was formally used in medicine as a germicide
Molybdenum Test results Yrs. 2013 & 2015	Range = ND – 1.8	ppb	Naturally-occurring element found in oreos and present in plants, animals and bacteria; commonly used form molybdenum trioxide used as a chemical reagent
Strontium Test results Yrs. 2013 & 2015	Range = 76- 690	ppb	Naturally-occurring element; historically commercial use of strontium has been in the faceplate glass of cathode-ray tube televisions to block x-ray emissions
Vanadium Test results Yrs. 2013 & 2015	Range = ND - 2	ppb	Naturally-occurring element metal; used as vanadium pentoxide which is a chemical intermediate and a catalyst
N-nitrosopyrrolidine (NPYR) Test results Yrs. 2008 & 2009	Range = ND – 0.002	ppb	Nitrosamines can form as intermediates and byproducts in chemical synthesis and manufacture of rubber, leather and plastics.
Perfluorooctanic Acid (PFOA) Test results Yrs. 2011& 2015	Range = ND – 0.02	ppb	Man –made chemical used in the manufacture of fluoropolymers.