

# BOROUGH OF CALDWELL

Caldwell Firehouse

30 Roseland Avenue

- Current Building Use: *Fire Department/Public Meeting Space*
- Current Overall Condition: *Fair*
- Current Building Status: *Usable*
- Current Building Issues:

	Urgent -->		Less Urgent		
	1	2	3	4	5
-Rear 2 <sup>nd</sup> floor door, exterior concrete and steel stairs need repair.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
-No ADA access to second floor conference room/ public space	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
- Generator works but is 40 years old.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
-Roof leaks in apparatus floor area.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
- 2 <sup>nd</sup> floor side exit door in conference room has no landing due to parking deck removal.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>