

BOROUGH OF CALDWELL

HEALTH & HUMAN SERVICES/SENIOR CITIZEN CENTER

24 Smull Avenue

- Current Building Use: *Human Services/ Food Pantry*
- Current Overall Condition: *Fair*
- Current Building Status: *Usable/Occupied*
- Current Building Issues:

	Urgent ->		Less Urgent		
	1	2	3	4	5
-Needs new roof (missing & buckled shingles).	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
-Needs gutters cleaned.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
- Needs exterior painting.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-Fire extinguishers need current inspection tags.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
-Ceiling tiles missing in basement.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
-Basement gas meter cabinet should have label (gas meter shut off).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-Second floor bathroom is inoperable (water shut-off due to leaks).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-Second floor radiators cracked and removed in two rooms.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>